



ICE REPORT D4.4.1: IMPACT OF COMMERCIAL OFFER

03/12/2021











Task T4.4:

Promotion of commercial offer to isolated territories

Lead: Marine South East













2

Contents

1	Intro	oduction4
	1.1	The ICE project
	1.2	Purpose of this document4
	1.3	Content of this Document5
2	Met	hodology6
	2.1	Planning6
	2.2	Financing6
	2.3	Grid Design & Engineering6
	2.4	Procurement7
	2.5	Facility Installation7
	2.6	Operation7
3	Alde	erney8
	3.1	Planning8
	3.2	Financing9
	3.3	Grid Design & Engineering9
	3.4	Procurement
	3.5	Facility Installation
	3.6	Operation
4	Isles	of Scilly
	4.1	Planning12
	4.2	Financing13
	4.3	Grid Design & Engineering13
	4.4	Procurement14
	4.5	Facility Installation15
	4.6	Operation
5	Mol	ène17
	5.1	Planning17
	5.2	Financing17
	5.3	Grid Design & Engineering
	5.4	Procurement
	5.5	Facility Installation19
	5.6	Operation19
6	Port	smouth International Port

TEXTER DINNERSHY UEA marine



BRETAGNE® DEVELOPPEMENT INNOVATION

534 Q

	6.1	Planning	21
	6.2	Financing	21
	6.3	Grid Design & Engineering	22
	6.4	Procurement	22
	6.5	Facility Installation	23
	6.6	Operation	23
7	Con	clusions	24











1 Introduction

1.1 The ICE project

Supported by Interreg VA France (Channel) England, the Intelligent Community Energy (ICE) project aims to facilitate the design and the implementation of innovative smart energy solutions for isolated territories that face unique energy challenges, and test these in the Channel area.

Many islands have no connection to wider electricity distribution systems and are dependent on imported energy supplies, typically both expensive and fossil fuel driven. The energy systems on which isolated communities are dependent tend to be less reliable, have high unit cost and produce more greenhouse gas (GHG) emissions per unit energy than mainland grid systems.

In response to these problems, the ICE project considers the entire energy cycle, specifically for our test sites, but also generally in terms of applying a general approach to other isolated communities. This assessment covers production to consumption and integrates new and established technologies in order to deliver innovative energy system solutions. These solutions will be implemented and tested at our unique pilot demonstration sites (Ushant island and the University of East Anglia's campus), to demonstrate their feasibility and to develop a general model for isolated smart energy systems elsewhere.

The ICE consortium brings together research and business support organisations in France and the United Kingdom. Commitment from SMEs will support the project rollout and promote European cooperation.

1.2 Purpose of this document

An important output from the ICE project is a refined methodology for implementing an integrated community energy scheme and the commercial offer to territories where the methodology could be deployed, as reported in deliverable D4.2.1. This outlines a value proposition addressing a sequence of steps performed along the timeline of the scheme implementation, including:

- 1. Planning and surveying, to assess both the resources available and the consenting needed;
- 2. Financing to build a viable case for investment and associated business model
- 3. Grid design and engineering, including modelling of the planned system for optimisation of overall performance
- 4. Procurement of the required equipment and services, including a main contractor to oversee the whole implementation
- 5. Installation of facilities including renewable energy assets, storage, network reinforcement
- 6. Operation of the new energy scheme.

In parallel with the methodology development and refinement, the ICE project has also engaged a wide community of territories where the ICE methodology could be applied. These territories are highly diverse, in terms of their energy needs, the maturity of their plans for decarbonisation and their political structures. In order to assess the value of promoting the ICE methodology to such territories, some pilot studies have been conducted. These have focused on a limited number of the priority territories identified in deliverable D4.3.1.

TTER



The results of these studies form a useful review of the potential impact of ICE methology on promotion and deployment, and are presented in this report.

1.3 Content of this Document

The document presents the results of the above approach for four territories, comprising two UK islands, one French island and a port. Based on these results, some conclusions have been derived to indicate how the methodology could be effectively promoted in future.











2 Methodology

The overall approach is to assess how the ICE methodology could be applied and promoted to the situation in selected territories. To do this, the work will make use of:

- The value proposition developed in deliverable D4.2.1
- The information on priority territories gathered and collated in D4.3.1 and other ICE work packages.

A template has been developed to capture relevant information in a consistent way. This template includes the headings defined within the ICE methodology, under the following headings.

2.1 Planning

Early stage planning is crucial to assessing the viability of the project and its potential impacts. This section is designed to determine where the project is currently in its planning timeline, in order to highlight key steps that need to happen next. It includes:

- Project Rationale: Are the main local or regional drivers for decarbonisation understood, clearly or partly?
- Resource Assessment: Does data on the accessible renewable resource exist or is it planned?
- Public Consultation: Is there evidence of public support for the project, or is engagement planned?
- Surveying & Consenting: What is the status of the consenting process, and of the required surveying?

2.2 Financing

The community energy scheme requires up-front capital investment which can be justified against cost savings and other benefits once the scheme is operating. The source of this capital could be private or public, depending on the ownership of the existing distribution network. Hybrid models (eg involving grant support) are also possible. This section seeks to understand the current thinking on capital investment options. It includes:

• Status of Financial Plan: Has the project identified a source of capital investment? What kind of business models have been considered, if any?

2.3 Grid Design & Engineering

Micro-grid performance requires careful optimisation to ensure that intermittent energy resources are utilised as fully as possible, whilst also meeting the requirements of energy users, at least cost. This section captures the current position in terms of preparation and/or delivery of the necessary assessment and optimisation. It includes:

• Design & Engineering: Has any analysis of the energy system been performed, either at high level or detailed modelling? Is a contractor identified to do this work?





2.4 Procurement

This section aims to capture the extent to which the project has considered the supply chain expertise required for implementation. A lot of experience is available from key suppliers so the project can benefit from pre-procurement dialogue leading on to a tendering procedure. Gaps in activity in the area can be usefully addressed within the ICE methodology. It includes:

- Generation Assets: What range of renewable energy assets are being targeted? Are they commercial scale (eg wind, tidal) or domestic scale (eg roof-top solar)?
- Storage Assets: Has any consideration been given to energy storage (eg batteries, hydro). If so, has optimal storage capacity been analysed?
- Network & Interfaces: Has integration with the existing distribution network been explored? Is the network owner supportive? What further network investment is needed?
- Control & Monitoring: Is there potential for smart grid functions (eg demand-side response, peer-to-peer trading)? Have these options been considered?

2.5 Facility Installation

A significant programme of installation is required, potentially including offshore or nearshore installation of marine energy devices. Although a major contractor is likely to lead, some of this work could involve local sub-contractors. Understanding this can support community engagement and this section is intended to capture the current status. It includes:

• Installation: Is the project engaging with any large contractors who would be interested to bid? Has dialogue been promoted with the local supply chain?

2.6 Operation

This section captures the level of understanding of activities needed during the life of the new facilities. This operational phase of the scheme life cycle is of particular relevance to local service providers, since it will provide business potential for several decades. It includes:

- Logistics: Do the existing project stakeholders have access to resources needed to operate the major assets reliably?
- Maintenance: Distribution and monitoring equipment is highly dispersed and requires 'white van' resources. Do these exist?
- Billing: How will the proposed system operation mesh with existing customer services? Have new support facilities been considered?
- Management: Will these customer services be part of a wider management oversight? Has this been considered?











3 Alderney

Territory Details	Island of Alderney within the Channel Islands, UK
Name of territory and the	
region	

The information is collected under the headings defined within the ICE methodology, using the tables below.

3.1 Planning

S.I Hammig	
Project Rationale	Alderney's average electricity demand is ~0.76 MW, with a peak of
Are the main local or regional	less than 1.5 MW. Alderney residents pay ~45 p/kWh, of which ~15
drivers for decarbonisation	p/kWh covers the cost of the diesel. If the levelized cost of energy
understood, clearly or partly?	from renewable sources is lower than 15 p/kWh, there is scope to
	reduce diesel generation utilisation, reducing costs and emissions.
	Deploying renewable generation also diversifies the energy mix,
	reducing consumers exposure to volatile fossil fuel prices. Analysis
	indicates that it is viable to deploy PV and wind turbine generation
	on Alderney for less than 15 p/kWh.
	With no renewable generation within the total electricity demand
	of ~6 GWh/annum, the carbon emissions from the diesel gensets is
	around 1,600 T CO2e/annum. Around 20 GWh/annum of heating
	energy is also consumed, supplied by various fossil fuels.
<u>Resource Assessment</u>	Yes, a significant amount of resource assessment has been
Does data on the accessible	performed, covering onshore wind, solar and marine current.
renewable resource exist or is	There is sufficient renewable resource to supply the island's
it planned?	electricity generation needs. Less than 100% renewable generation
	will be optimal, given the existence of the diesel gensets which have
	recently been upgraded.
	Deployment of renewable generation at household level is likely to
	be a problem on Alderney, since the relatively high fixed costs of the network would have to be met from an ever-smaller base of
	customers. Community schemes which contribute to overall
	network resilience and stability are likely to be preferrable.
Public Consultation	Public engagement on the potential investment projects is
Is there evidence of public	fragmented. The State of Alderney has been exploring the prospect
support for the project, or is	of a major tidal stream investment for some years, but has not yet
engagement planned?	succeeded in getting underway. The civic community meanwhile is
	keen to advance in a more incremental way, with a succession of
	smaller projects. External facilitation under ICE could usefully
	integrate these initiatives under a single plan, rolled out over a
	range of time-scales. The level of interest suggests a significant
	amount of public support for action. However, strong controversy
	has been generated by publication of outline plans for a large
	French-led tidal energy project without clear benefits to Alderney.
Surveying & Consenting	There has not yet been any significant survey work done to address
What is the status of the	consenting requirements for tidal stream, wind or solar
and the second of the	dealer warden in the Physical Advances of the second definition of the second sec
consenting process, and of the required surveying?	deployments. It is likely that any future tidal stream array would piggy-back on a potential project in French territorial waters, for











which surveying has been completed. Small scale solar
deployments are unlikely to incur significant consenting barriers.
However, onshore wind turbines would require careful siting and
planning approvals.
Minute-by-minute electricity demand profiles are not available on
Alderney and this greatly limits the assessment of cost-
effectiveness of decarbonisation measures. It is likely that short-
term peaks require more capacity than would otherwise be
recognised, while short-term dips are likely to result in reduced
generator efficiency. Access to real-time demand data is a key
requirement for future optimisation of the system.

3.2 Financing

Status of Financial Plan	Recent investments in the electricity network have been funded
Has the project identified a	with support from the States of Alderney: a finance and lease-back
source of capital investment?	arrangement, or a commercial load guaranteed by the States of
What kind of business models	Alderney. Either way, the operating company (AEL) has been able
have been considered, if any?	to benefit from public sector lending rates. In both cases, it is
	essential that the project is able to generate returns that can
	support the case for investment. In the case of the large tidal array
	proposal (under a French contractor) a Power Purchase Agreement
	is envisaged which specifies an annual energy draw-down by
	Alderney at a fixed cost per kWh. Similar financing models should
	be available for future renewable generation and storage
	developments, provided robust financial projections can be
	defined.

3.3 Grid Design & Engineering

Design & Engineering	The ICE project has demonstrated the vital importance of modelling
Has any analysis of the	to ensure that the dynamic nature of both demand and renewable
energy system been	generation can be accommodated cost-effectively. A specific study
performed, either at high	on Alderney has been performed. This was able to utilise a
level or detailed modelling?	significant amount of previous analysis of the dynamic electricity
Is a contractor identified to	demand on Alderney.
do this work?	As a result, there is a good understanding of the likely levels of
	renewable energy penetration and of the associated electricity
	storage requirements on Alderney. An initial estimate of system
	optimisation indicates: 250kW of PV solar + 750kW of onshore
	wind, with a 1.5MW battery (6MWh capacity) could support 50%
	renewables penetration. Without the battery, renewables
	penetration would likely be limited to around 30% before
	curtailment losses become onerous.
	Further analysis will be needed for detailed engineering
	optimisation, but the current state of knowledge will allow
	selection from a wide range of competent contractors.











3.4 Procurement

<u>Generation Assets</u> What range of renewable energy assets are being targeted? Are they commercial scale (eg wind, tidal) or domestic scale (eg roof-top solar)?	In the short term, modest onshore community-scale RE deployments are most likely. These would need to be integrated within AEL's existing network and business model. Wind and PV solar are the most likely assets to be investable, in the 100's kW power range. In the longer term, it is likely that larger tidal energy projects will be implemented, probably as part of (or linked to) the proposed French tidal scheme, FABlink. Some export potential of an Alderney-only tidal energy scheme will probably be essential to economic viability.
<u>Storage Assets</u> Has any consideration been given to energy storage (eg batteries, hydro). If so, has optimal storage capacity been analysed?	There are no existing plans to install energy storage on Alderney. The 8 diesel generators are sufficient to meet peak load, so the business case for using the battery to meet peak load (and running the generators nearer to optimal design speed) no longer exists. A good case for energy storage would be created, however, when the island starts to install renewable generating assets. Modelling suggests a battery rating of 1.5MW (with 4 hour duration) would be the approx. size, but more detailed modelling would be helpful to refine the complete system operation.
<u>Network & Interfaces</u> Has integration with the existing distribution network been explored? Is the network owner supportive? What further network investment is needed?	AEL has been shown to be receptive to proposals that could reduce dependency on imported diesel fuel. They are keen to avoid residents going 'off-grid' as this would increase network fixed costs for other customers. A community scheme could be attractive, with a Power Purchase Agreement by AEL to attract low-cost financing. Such a project is likely to include some network reinforcement in order to maintain or enhance the resilience of the system.
<u>Control & Monitoring</u> Is there potential for smart grid functions (eg demand- side response, peer-to-peer trading)? Have these options been considered?	AEL already offers tariffs that incentivise consumption during periods of low demand, but there is significant further potential, especially as domestic and EV energy storage becomes available. Such systems will require controls that optimise the use of such storage. With a battery storage facility included within future renewable energy generation projects, the need for further control and monitoring will be essential to manage the state of charge of the battery. Demand monitoring in real time will be an important element of this system, and will also generate useful datasets for optimising the system design.

3.5 Facility Installation

Installation	No contractors have been approached directly. However, a
Is the project engaging with	contractor is in place for the proposed French-led tidal stream
any large contractors who	development project. A dedicated contractor is likely to be
would be interested to bid?	preferred for the onshore development scenarios, specialist in
Has dialogue been promoted	deployment of onshore wind and PV solar farms. There are many
with the local supply chain?	suitable contractors in the UK.











3.6 Operation

Logistics	AEL have capacity in operating the existing network and diesel
Do the existing project	generators. This could potentially be extended to include logistics
stakeholders have access to	services for new assets such as battery storage. Spares inventory
resources needed to operate	for wind turbine maintenance is specialist and is likely to use an
the major assets reliably?	external contractor.
Maintenance	AEL have capacity for maintenance of their existing network, and
Distribution and monitoring	this could be expanded to cover the network extensions. Additional
equipment is highly dispersed	specialist expertise is likely to be needed for planned maintenance
and requires 'white van'	of turbines, solar PV and batteries.
resources. Do these exist?	
<u>Billing</u>	It is anticipated that AEL's existing billing system would be adapted
How will the proposed system	where necessary.
operation mesh with existing	
customer services? Have new	
support facilities been	
considered?	
Management	No major additions to customer services beyond those already
Will these customer services	provided by AEL are envisaged.
be part of a wider	
management oversight? Has	
this been considered?	











4 Isles of Scilly

Territory Details	Isles of Scilly, UK
Name of territory and the	
region	

The information is collected under the headings defined within the ICE methodology, using the tables below.

4.1 Planning

Early stage planning is crucial to assessing the viability of the project and its potential impacts. This section is designed to determine where the project is currently in its planning timeline, in order to highlight key steps that need to happen next.

<u>Project Rationale</u> Are the main local or regional drivers for decarbonisation understood, clearly or partly?	The Isles of Scilly (IoS) is archipelago of 140 small islands off the coast of Cornwall, around 45km west of Land's End, Cornwall. The five main inhabited islands are St Mary's, Tresco, Bryher, St Martin's and St Agnes [1]. The largest inhabited island is St Mary's which is the main settlement of the islands. The small scale of demand, large seasonal variations in demand, lack of available energy resources and heritage restrictions on development, are common for small island communities. Further, IoS has a high share of fuel poverty (22.4%, against the UK national average of 10.4%).
<u>Resource Assessment</u> Does data on the accessible	The IoS is almost entirely reliant on electricity imported from the mainland, with 457 kWp of solar PV installed on the islands which is
renewable resource exist or is it planned?	likely to generate around 2.6% of the total electricity demand (485,791 kWh/year). The IoS are connected to the mainland electricity via a single 33kV cable with a capacity of 7.5MW (installed
	in 1989 by Western Power Distribution, WPD).
	We carried out an assessment of potential as part of the ICE project.
	Concerning solar, The direct normal irradiation (DNI) received is
	expected to be 1062 KWh/m ² /year, the global horizontal irradiation (GHI) is 1145 KWh/m ² /year and on a plane of 37° 1326
	KWh/m ² /year. However, there are land constraints on exploiting
	this. We estimate that there are 1,182 domestic rooftops and we
	identified 54 warehouses and barns with roofs potentially suitable for solar PV as well as ground mounted opportunities.
	Opportunities for wind energy are likely to be limited by the
	classification of much if the islands as protected zones and due to
	visual impact. We modelled the use of smaller scale turbines
	(100kW & 250kW). The available wind resource is good, with modelling suggest consistent impacts across the year. It is
	impossible to suggest a meaningful figure for achievable wind
	energy exploitation given the current unlikelihood of achieving
	planning permission in the UK.
	Moixa, a private company, began to install battery storage on the
	islands in 2018, and there is considerable potential for more DSR improvements on the island.



RETACH

DEVELOPPEMENT



E)

Public Consultation	Full stakeholder engagement was not possible within this study due
Is there evidence of public	to time and resource constraints and severely complicated by the
support for the project, or is	Covid-19 pandemic from February 2020. In this study, we were able
engagement planned?	to integrate some IoS Council objectives based on a review of
	publicly available strategies and plans. The Council has been
	involved in an islands wide initiative to make energy smarter.
Surveying & Consenting	There has not yet been any significant survey work done to address
What is the status of the	consenting requirements for wind or solar deployments.
consenting process, and of	Total energy consumption on the IoS is approximately 18.732GWh
the required surveying?	and the average power demand for a year is 2.14MW. The
	maximum recorded power demand is 4.92MW, occurring at around
	7 pm in mid-April. Peak power demand is typically from 6 pm to 7
	pm. Despite the IoS being connected to the UK national grid, there
	were seven total power blackouts during 2019 for at least 30
	minutes (April, July, August, September and October). This due to
	the faults on the islands grid cable [11].

4.2 Financing

The community energy scheme requires up-front capital investment which can be justified against cost savings and other benefits once the scheme is operating. The source of this capital could be private or public, depending on the ownership of the existing distribution network. Hybrid models (eg involving grant support) are also possible. This section seeks to understand the current thinking on capital investment options.

Status of Financial Plan	No, we did not see this as within the purview for our assessment.
Has the project identified a	Some consideration was given to options within the UK funding
source of capital investment?	structures, but these are limited and would require further
What kind of business models	investigation as to relevance.
have been considered, if any?	

4.3 Grid Design & Engineering

RRETACN

DEVELOPPEMENT

Micro-grid performance requires careful optimisation to ensure that intermittent energy resources are utilised as fully as possible, whilst also meeting the requirements of energy users, at least cost. This section captures the current position in terms of preparation and/or delivery of the necessary assessment and optimisation.

Design & Engineering	An assessment was carried out of the network capacity and limitations
Has any analysis of the	of the IoS electrical network.
energy system been	Western Power Distribution (WPD) is the electrical power provider to
performed, either at high	IoS through a 33kV subsea cable with a capacity of 7.5MW. There is a
level or detailed	diesel-fuelled power station consisting of seven individual generation
modelling? Is a contractor	sets on Hospital Lane on St Mary's. They are used for less than
identified to do this work?	200hours/year. The sub-sea cable is fed from Cornwall and terminated
	at St Mary's power station, 33 kV. There are four 11kV feeders which
	supply power to the islands.
	The island network voltage is 11kV is the network voltage. The network
	is a mix of overhead and underground lines on the land and sub-sea
	cables. The 11kV is converted to a nominal 230V and 415V for

PLYMOUTH UNIVERSIT

TTER

marine





able and g a secon oS includ mends se and swhe onnection emand is r flow and e highest r rate (0.2 it has on . Tresco	has his has his des an a some sc here St M h point s 4.92M d reliabili t voltag 2442/yea has the ops and ore depth	storically from 20 assessme renario a lary's is to the W. Tabl ity asses e drops ar). This supply fe e highes able ca n in Appe	y been 23 which analysis the bigg Cornwa le 10 su sment f (2.06% because eeder fr st powe pacity a endix 1	reliable. ch will co system r s, prefera gest islan all mainl ummarise or the fou (or the fou))))))))))))))))))))))))))))))))))))	The 33kV WPD is st tens of reliability, ably with d and it is and. The es all the ur islands. capacity ies a part artin's, at nd, 3951 yher. The
g a secon oS includ mends second ands whe onnection emand is r flow and e highest rate (0.2 it has on . Tresco oltage dro s into mor	nd cable des an a some sc nere St M n point s 4.92M d reliabili t voltage 2442/yea nly one s has the ops and ore depth	from 20 assessme enario a lary's is to the W. Tabl ity asses e drops ar). This supply fe e highes able ca n in Appe	23 which ent of analysis the bigg Cornwa le 10 su sment f (2.06% because eeder fr st powe pacity a endix 1	ch will co system r s, prefera all mainl ummarise or the fou (or the fou))))))))))))))))))))))))))))))))))))	st tens of reliability, ably with d and it is and. The es all the ur islands. capacity ies a part artin's, at nd, 3951
oS includ mends so pands who production emand is r flow and e highest rate (0.2 it has on . Tresco oltage dro s into mor	des an a some sc here St M h point s 4.92M d reliabili t voltag 2442/yea hly one s has the ops and ore depth	assessmo enario a to the W. Tabl ity asses e drops ar). This supply fe e highes able ca n in Appe	ent of analysis the bigg Cornwa le 10 si sment f (2.06% because eeder fr st powe pacity a endix 1	system r s, prefera all mainl ummarise or the fou (or the fou (or the suppl or the suppl or St M er dema are in Br	reliability, ably with d and it is and. The es all the ur islands. capacity ies a part artin's, at nd, 3951
mends so and some mand is r flow and e highest rate (0.2 it has on . Tresco oltage dro s into mor	some sc nere St M n point s 4.92M d reliabili t voltag 2442/yea hly one s has the ops and ore depth	enario a lary's is to the W. Tabl ity asses e drops ar). This supply fe e highes able ca n in Appe	analysis the bigg Cornwa le 10 si sment f (2.06% because eeder fr st powe pacity a endix 1	gest islan all mainl ummarise or the fou (o), cable e it suppl om St M er dema are in Br	ably with d and it is and. The es all the ur islands. capacity ies a part artin's, at nd, 3951
mends so and some mand is r flow and e highest rate (0.2 it has on . Tresco oltage dro s into mor	some sc nere St M n point s 4.92M d reliabili t voltag 2442/yea hly one s has the ops and ore depth	enario a lary's is to the W. Tabl ity asses e drops ar). This supply fe e highes able ca n in Appe	analysis the bigg Cornwa le 10 si sment f (2.06% because eeder fr st powe pacity a endix 1	gest islan all mainl ummarise or the fou (o), cable e it suppl om St M er dema are in Br	ably with d and it is and. The es all the ur islands. capacity ies a part artin's, at nd, 3951
lands who onnection emand is r flow and e highest rate (0.2 it has on . Tresco oltage dro s into mor	nere St M point 4.92M dreliabili t voltag 2442/yea nly one s has the ops and ore depth	fary's is to the W. Tabl ity asses e drops ar). This supply fe e highes able ca n in Appe	the bigg Cornwa sment f (2.06% because eeder fr st powe pacity a endix 1	gest islan all mainl ummarise or the fou (or the fou))))))))))))))))))))))))))))))))))))	d and it is and. The es all the ur islands. capacity ies a part artin's, at nd, 3951
onnection emand is r flow and e highest rate (0.2 it has on . Tresco oltage dro s into mor	n point 5 4.92M d reliabili t voltag 2442/yea nly one s has the ops and ore depth	to the W. Tabl ity asses e drops ar). This supply fe e highes able ca n in Appe	Cornwa le 10 si sment f (2.06% because eeder fr st powe pacity a endix 1	all mainl ummarise or the fou 6), cable e it suppl om St M er dema are in Br	and. The es all the ur islands. capacity ies a part artin's, at nd, 3951
emand is r flow and e highest rate (0.2 it has on . Tresco oltage dro s into mor	s 4.92M ¹ d reliabili t voltage 2442/yea hly one s has the ops and ore depth	W. Tabl ity asses e drops ar). This supply fe e highes able ca n in Appe	le 10 si sment f (2.06% because eeder fr st powe pacity a endix 1	ummarise for the fou (6), cable e it suppl om St M er dema are in Br	es all the ur islands. capacity ies a part artin's, at nd, 3951
emand is r flow and e highest rate (0.2 it has on . Tresco oltage dro s into mor	s 4.92M ¹ d reliabili t voltage 2442/yea hly one s has the ops and ore depth	W. Tabl ity asses e drops ar). This supply fe e highes able ca n in Appe	le 10 si sment f (2.06% because eeder fr st powe pacity a endix 1	ummarise for the fou (6), cable e it suppl om St M er dema are in Br	es all the ur islands. capacity ies a part artin's, at nd, 3951
e highest rate (0.2 it has on . Tresco oltage dro s into mor	t voltag 2442/yea nly one s has the ops and ore depth	e drops ar). This supply fe e highes able ca n in Appe	(2.06% because eeder fr st powe pacity a endix 1	6), cable e it suppl om St M er dema are in Br	capacity ies a part artin's, at nd, 3951
e highest rate (0.2 it has on . Tresco oltage dro s into mor	t voltag 2442/yea nly one s has the ops and ore depth	e drops ar). This supply fe e highes able ca n in Appe	(2.06% because eeder fr st powe pacity a endix 1	6), cable e it suppl om St M er dema are in Br	capacity ies a part artin's, at nd, 3951
rate (0.2 it has on . Tresco oltage dro s into mor	2442/yea hly one s has the ops and pre depth	ar). This supply fe e highes able ca n in Appe	because eeder fr st powe pacity a endix 1	e it suppl om St M er dema are in Br	ies a part artin's, at nd, 3951
it has on . Tresco oltage dro s into mor	nly one s has the ops and ore depth	supply fe e highes able ca n in Appe	eeder fr st powe pacity a endix 1	om St M er dema are in Br	artin's, at nd, 3951
. Tresco oltage dro s into mor	has the ops and ore depth	e highes able ca n in Appe	st powe pacity a endix 1	er dema are in Br	nd, 3951
oltage dro s into mor	ops and ore depth	able ca n in Appe	pacity a endix 1	are in Br	
s into mor	re depth	n in Appe	endix 1		, –
	flow and				
10 - Power y	-	reliability	assessme	ents	
-					
	LO	ad node			
Volta	age	Cable ca	apacity	Failure	rate per
drop	[kV]	[%	5]	ye	ar
Max	Min	Max	Min	Max	Min
0.17%	0.15%	7.76%	0.34%	0.2436	0.2254
0 39%	0 35%	7 12%	1 2%	0 2385	0.2111
0.0070	0.5570	7.1270	1.270	0.2303	0.2111
1.06%	0 87%	19 3/1%	2 67%	0 2442	0 1337
1.00%	0.0770	19.3470	2.0770	0.2442	0.1007
0.88%	0.21%	17.96%	0.62%	0.14131	0.09287
0.88%	0.21%	17.96%	0.62%	0.14131	
g	Max 0.17% 0.39% 1.06% 0.88%	0.17% 0.15% 0.39% 0.35% 1.06% 0.87% 0.88% 0.21%	Max Min Max 0.17% 0.15% 7.76% 0.39% 0.35% 7.12% 1.06% 0.87% 19.34% 0.88% 0.21% 17.96%	Max Min Max Min 0.17% 0.15% 7.76% 0.34% 0.39% 0.35% 7.12% 1.2% 1.06% 0.87% 19.34% 2.67% 0.88% 0.21% 17.96% 0.62%	Max Min Max Min Max 0.17% 0.15% 7.76% 0.34% 0.2436 0.39% 0.35% 7.12% 1.2% 0.2385 1.06% 0.87% 19.34% 2.67% 0.2442

4.4 Procurement

This section aims to capture the extent to which the project has considered the supply chain expertise required for implementation. A lot of experience is available from key suppliers so the project can benefit from pre-procurement dialogue leading on to a tendering procedure. Gaps in activity in the area can be usefully addressed within the ICE methodology.

Generation Assets	The overall picture which emerged from our capacity mapping was
What range of renewable	that capacity on the IoS is limited to a small number of generalised
energy assets are being	skills (e.g., construction) with increasing evidence of more specialist
targeted? Are they	capacities in West Cornwall, and more again when including all of
commercial scale (eg wind,	Cornwall or the Southwest UK. Some notable exceptions were the
tidal) or domestic scale (eg	Isles of Scilly Wildlife Trust who provide specialist environmental
roof-top solar)?	consultancy on the islands whilst, on the other hand, there was no
	evidence of electricians based on the islands, though there were

TTER UNIVERSIT

E

LEA marine



BRETAGNE

DEVELOPPEMENT



14

	plenty in accessible Penzance and nearby West Cornwall. For more detail on the local capacity mapping see Appendix 1.
Storage Assets	Moixa, a smart system company, began installing 43.8kWh of
Has any consideration been	battery storage to help optimise the energy system in 2018.
given to energy storage (eg	
batteries, hydro). If so, has	
optimal storage capacity	
been analysed?	
<u>Network & Interfaces</u>	We did not seek an opinion from WPD. Any change in behaviour
Has integration with the	would have to come from a position where WPD could see a return
existing distribution network	on investment and where spend as allowable.
been explored? Is the	
network owner supportive?	
What further network	
investment is needed?	
Control & Monitoring	There is some discussion of the early stages of the switch from DNO
Is there potential for smart	to DSO functionality but at time of writing it was too early to add
grid functions (eg demand-	detail of what this might mean in practical terms.
side response, peer-to-peer	
trading)? Have these options	
been considered?	

4.5 Facility Installation

A significant programme of installation is required, potentially including offshore or nearshore installation of marine energy devices. Although a major contractor is likely to lead, some of this work could involve local sub-contractors. Understanding this can support community engagement and this section is intended to capture the current status.

Installation	No. However, the IoS has a smart grid programme that sees the
Is the project engaging with	island work with Hitachi.
any large contractors who	
would be interested to bid?	
Has dialogue been promoted	
with the local supply chain?	

4.6 Operation

This section captures the level of understanding of activities needed during the life of the new facilities. This operational phase of the scheme life cycle is of particular relevance to local service providers, since it will provide business potential for several decades.

Logistics Do the existing project stakeholders have access to resources needed to operate the major assets reliably?	
Maintenance	This level of detail was not considered.
Distribution and monitoring	
equipment is highly dispersed	

TTER





and requires 'white van'	
resources. Do these exist?	
<u>Billing</u>	This level of detail was not considered.
How will the proposed system	
operation mesh with existing	
customer services? Have new	
support facilities been	
considered?	
<u>Management</u>	This level of detail was not considered.
Will these customer services	
be part of a wider	
management oversight? Has	
this been considered?	











5 Molène

Name of territory and the region	Isle of Molène Island located off the west coast of Finistère, in Brittany, France. Surface area of 72ha. 131 inhabitants.
	Non interconnected island.

The information is collected under the headings defined within the ICE methodology, using the tables below.

5.1 Planning

Early stage planning is crucial to assessing the viability of the project and its potential impacts. This section is designed to determine where the project is currently in its planning timeline, in order to highlight key steps that need to happen next.

Project Rationale	The island of Molène is part of the Ponant Islands which have been
Are the main local or regional	involved for many years with local and regional partners in the
drivers for decarbonisation	energy transition of their territories and are involved in discussions
understood, clearly or partly?	to this effect through notably the Ponant Islands Association.
<u>Resource Assessment</u>	Yes, some data is available following the links below:
Does data on the accessible	Data about current energy production mix : <u>https://opendata-iles-</u>
renewable resource exist or is	ponant.edf.fr/pages/home/
it planned?	Data about objectives of Energy transition :
	https://www.ecologie.gouv.fr/sites/default/files/20200422%20Pr
	ogrammation%20pluriannuelle%20de%20l%27e%CC%81nergie.pd
	<u>f</u> page 384
Public Consultation	Yes, meetings have been done (latest on 24 th April 2022), and
Is there evidence of public	communication in Association des Iles du Ponant's yearly journal
support for the project, or is	(https://www.iles-du-ponant.com/wp-
engagement planned?	<pre>content/uploads/2021/06/JOURNAL-DES-ILES-2021.pdf</pre>

5.2 Financing

The community energy scheme requires up-front capital investment which can be justified against cost savings and other benefits once the scheme is operating. The source of this capital could be private or public, depending ownership of the existing distribution network. Hybrid models (eg involving grant support) are also possible. This section seeks to understand the current thinking on capital investment options.

Status of Financial Plan	There is no concrete project planned for now.
Has the project identified a	
source of capital investment?	
What kind of business models	
have been considered, if any?	

CTER





5.3 Grid Design & Engineering

Micro-grid performance requires careful optimisation to ensure that intermittent energy resources are utilised as fully as possible, whilst also meeting the requirements of energy users, at least cost. This section captures the current position in terms of preparation and/or delivery of the necessary assessment and optimisation.

Design & Engineering	EDF SEI is the only authorized operator for energy production,
Has any analysis of the	transport and distribution.
energy system been	It is working on implementing an Energy Management System, plus
performed, either at high	Li-Ion Battery to ensure good addition of Renewable Energy
level or detailed modelling?	facilities.
Is a contractor identified to	They have detailed data about energy consumption of the island.
do this work?	French regulation do not allow EDF SEI to transmit all the data, but
	only small fraction of it (for example, for a 1h time scale, data for
	only 30 days can be communicate)

5.4 Procurement

This section aims to capture the extent to which the project has considered the supply chain expertise required for implementation. A lot of experience is available from key suppliers so the project can benefit from pre-procurement dialogue leading on to a tendering procedure. Gaps in activity in the area can be usefully addressed within the ICE methodology.

Generation Assets	Data about objectives of Energy transition :
What range of renewable	https://www.ecologie.gouv.fr/sites/default/files/20200422
energy assets are being	%20Programmation%20pluriannuelle%20de%20l%27énergie.pdf
targeted? Are they	page 384
commercial scale (eq wind,	
tidal) or domestic scale (eq	No precision is currently available about type of assets. It can be
roof-top solar)?	commercial scale or domestic.
	Actions have been done on both these scales so far.
<u>Storage Assets</u>	EDF SEI is working on implementing an Energy Management System,
Has any consideration been	plus Li-Ion Battery to ensure good addition of Renewable Energy
given to energy storage (eg	facilities, based on forecasted Ren. Energy project on study (for
batteries, hydro). If so, has	example the 700kWp SDEF project + 36 kWp SDEF project)
optimal storage capacity	
been analysed?	SDEF has launched a study about H2 storage, for the electricity
, i	surplus that cannot be stored by the Li-Ion Battery.
Network & Interfaces	Network owner is SDEF (since Molène transferred to SDEF the role
Has integration with the	of network maintenance and developpement).
existing distribution network	
been explored? Is the	EDF SEI has a 30 year contract with SDEF to operate the Molene
network owner supportive?	Network.
What further network	
investment is needed?	Investment are made for Ren Energy project for new line or
	upgraded line. No big investment planned since the grid is already
	existing, and that the evolution of consumption is limited (only
	replacement of production, not an increase or decrease in electricity
	consumption)

PLYMOUTH

TTER

marine



BRETAGN

DEVELOPPEMENT



	Also, network burying has long be done, since it is well developed in France, and moreover Molene was known for wind and storm, so it is already done.
<u>Control & Monitoring</u> Is there potential for smart grid functions (eg demand- side response, peer-to-peer	EDF SEI is the only authorized operator for energy production, transport and distribution. EDF SEI perform the role of monitoring.
trading)? Have these options been considered?	Any energy producer has to sell it's electricity to EDF (and EDF has to buy it), only after the national energy commission (CRE) has stated a feed-in tariff. Usually, the increase of cost for small project and on the remote area of the island doesn't make profitable such a project.
	The grid is not "open" like European grid, so there is not (yet) a competitive tariff between two sites or within the day.

5.5 Facility Installation

A significant programme of installation is required, potentially including offshore or nearshore installation of marine energy devices. Although a major contractor is likely to lead, some of this work could involve local sub-contractors. Understanding this can support community engagement and this section is intended to capture the current status.

Installation	No concrete project of marine energy for Molene so far.
Is the project engaging with	
any large contractors who	One study has been done regarding potential (based on current),
would be interested to bid?	but cost is high. The cost of electricity has been estimated twice the
Has dialogue been promoted	current cost with fuel genset.
with the local supply chain?	

5.6 Operation

This section captures the level of understanding of activities needed during the life of the new facilities. This operational phase of the scheme life cycle is of particular relevance to local service providers, since it will provide business potential for several decades.

Logistics Do the existing project stakeholders have access to resources needed to operate the major assets reliably?	Skilled workers come from the continent to install the PV for example. There is no company on Molene able to be part of an Ren. Project (not even an electrician for inhabitants).
<u>Maintenance</u> Distribution and monitoring equipment is highly dispersed and requires 'white van' resources. Do these exist?	Maintenance is made by people from the continent. With the example of Ushant, maintenance was nearly similar for 1 or 5 PV plants, since the workers have to come for the whole day on the island.
<u>Billing</u> How will the proposed system operation mesh with existing	No billing for now.









customer services? Have new support facilities been considered?	
<u>Management</u> Will these customer services be part of a wider management oversight? Has this been considered?	Molene is part of the Ponant Island and activities linked to energy transition are managed in association with Association des Iles du Ponant and coherently with what is done for Ushant and Sein.













6 Portsmouth International Port

Territory Details	Port area within the city of Portsmouth, UK
Name of territory and the	
region	

The information is collected under the headings defined within the ICE methodology, using the tables below.

6.1 Planning

Project Pationala	The port's existing energy system is facing severe challenges that
Project Rationale	
Are the main local or regional	need to be addressed with urgency. These are:
drivers for decarbonisation	 Port emissions are having a large impact on poor air quality
understood, clearly or partly?	in the city, primarily due to particulate and NOx emissions
	from ships and port machinery;
	• Ships are starting to require large amounts of power when
	at berth, and this demand exceeds the level of power
	available in the port.
	The problems are clearly understood, but it is unclear what
	solutions the port should invest in.
Resource Assessment	There is quite extensive data available on the solar power potential
Does data on the accessible	within the port. A survey has been conducted by Custom Solar and
renewable resource exist or is	approx. 1.2 MWp of new generating capacity is currently being
it planned?	installed. This is additional to around 600 kWp of existing PV solar.
n plaimea:	There is probably more potential PV solar generating capacity to be
	exploited in future.
	•
	Some assessment of wind turbine deployment options has also
	been performed, but this is not so attractive due to the height
	limitations imposed in this location.
Public Consultation	A considerable amount of public communication has been
Is there evidence of public	performed, but mainly at a high level, proposing generic goals
support for the project, or is	rather than specific investments. A strategic port master-plan has
engagement planned?	been published that includes some sustainability targets, but also
	at a high level.
Surveying & Consenting	Survey data is available at fine resolution, and a great deal is known
What is the status of the	about environmental status and renewable resource availability.
consenting process, and of	Planning consent for deployment of PV solar in the port is not
the required surveying?	required. However, planning consent for wind turbines or current
	turbines (attached to the quayside) would be required and has not
	yet been requested as there are no plans being actively developed
	for such installations.
	Port facilities that could export power to the grid require an
	additional G99 consent which has been obtained.
L	

6.2 Financing

RRETAGN

DEVELOPPEMENT

Status of Financial Plan	At present, the port is not seeking external investment. The port is
	wholly owned by Portsmouth City Council which can secure capital

TT DI. Te super-

Pages .





Has the project identified a source of capital investment? What kind of business models have been considered, if any?
--

6.3 Grid Design & Engineering

Design & Engineering	A significant amount of power consumption monitoring has been
Has any analysis of the	performed, and investment has been directed at reducing demand
energy system been	(eg by using all LED lighting and using a seawater heat pump for
performed, either at high	space heating). However, the power demand of visiting vessels is
level or detailed modelling?	unknown since even the vessel operator is often unaware of the
Is a contractor identified to	ship's consumption at berth. Electrification of port assets (eg
do this work?	cranes, freight tugs, link spans etc) will also create additional
	demand which is current not known accurately.

6.4 Procurement

Generation Assets What range of renewable energy assets are being targeted? Are they commercial scale (eg wind, tidal) or domestic scale (eg roof-top solar)?	As stated above, some solar PV facilities are already being installed at commercial scale. The scope for wind and current turbines is limited: both by planning constraints (wind) and the lack of much tidal stream or river current at the port.
<u>Storage Assets</u> Has any consideration been given to energy storage (eg batteries, hydro). If so, has optimal storage capacity been analysed?	Two storage facilities have already been installed: two dumb batteries (1 WMh Li-ion); and an intelligent PESO battery (150kWh lead-acid + Li-ion) with an AI-based controller for optimising the battery operation. These assets are principally for storing solar power and potentially for selling balancing services to the grid. It is recognised that much more storage will be needed to meet vessel power requirements.
<u>Network & Interfaces</u> Has integration with the existing distribution network been explored? Is the network owner supportive? What further network investment is needed?	Extensive discussions have been held with the local DNO (SSE). These have mainly concerned increasing the connection capacity for the port to meet vessel power requirements. However, it is unclear what connection rating will be required. Furthermore, the likely scale of additional capacity will exceed the power available and HV grid reinforcement will be needed. This will be very expensive. Although the DNO has been supportive, they have limited scope to deliver what the port will need.
Control & Monitoring	The port is also considering a private wire to a HV sub-station to bypass the DNO constraints. Yes, these options have been considered. The PESO AI-based controller can help to optimise provision of these services. It is

Inc.s



BRETAGNE DÉVELOPPEMENT INNOVATION



Is there potential for smart	likely that more asset consumption monitoring will be needed to
grid functions (eg demand-	provide inputs to the controller. This work has not yet been scoped
side response, peer-to-peer	and no contractor approached.
trading)? Have these options	
been considered?	

6.5 Facility Installation

Installation Is the project engaging with any large contractors who would be interested to bid? Has dialogue been promoted with the local supply chain?	The PV solar installation contractor is already in place. However, selection of the wider system installation contractor has not yet been considered. At present, it is not clear what kind of operating business model will be applied to the ports growing energy grid system. EV charging points are being supplied and installed by a contractor who will finance the investment against charging revenues.
	Other local suppliers are involved in related works, such as an air quality monitoring network.

6.6 Operation

•	
Logistics Do the existing project stakeholders have access to resources needed to operate the major assets reliably?	Probably not. It is likely that external maintenance providers will be needed, alongside internal port engineering expertise.
<u>Maintenance</u> Distribution and monitoring equipment is highly dispersed and requires 'white van' resources. Do these exist?	This is less applicable to the port since it is in a more compact area.
Billing How will the proposed system operation mesh with existing customer services? Have new support facilities been considered?	The billing model for visiting ships is not yet defined. Both a charge per MWh and a fixed price model are options. These will be integrated into port fees.
<u>Management</u> Will these customer services be part of a wider management oversight? Has this been considered?	Yes, the port is in active discussion with its customers, to agree the power provision services that could be made available. The port will continue to provide management oversight.









7 Conclusions

These results make it clear that the possible deployment territories are very diverse in terms of their needs and their maturity along the decarbonisation journey. Application of the ICE methodology will be varied, to reflect these differing requirements.

All of the territories have needs that are currently unmet. This is encouraging and suggests that ICE methodology has a role, even in relatively mature territories.

The port-type territories are potentially more easily managed than islands because there is already a unified port management structure in place. The port can also evaluate investment options in decarbonisation more easily as future revenue streams are more easily predicted (based on numbers of visiting ships and other factors where the port has good quality information).

- Most ports have existing supply chains already in place so suitable expertise can be accessed. Socio-economic benefits of building supply chain growth based on decarbonisation can also be analysed reasonably easily.
- Although the Port of Portsmouth (being publicly owned) has achieved good levels of public engagement, it is likely that privately owned ports will need much more assistance in this area. ICE can help point the way in the area.

The island territories range from those having well-developed strategies in place, backed up by significant monitoring data, and those only just starting on the road to decarbonisation. The larger islands are generally more advanced.

Smaller islands are often at an early stage, with much more limited resources to work with. ICE methodology has a more clearly defined role here as small island communities will be able to benefit significantly from the experience embedded in ICE. On small islands, a group of committed citizens can achieve a disproportionate amount of progress, using the island community networks. However, this progress needs careful guidance to overcome the lack of technical expertise that exists in most small island communities.









